

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 7)**

Water Level of the accumulated water (at 7:00 on September 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,197 mm (33 mm decrease since 16:00 on September 6)	O.P.+ 3,159 mm (27 mm increase since 16:00 on September 6)	—
	Water level of Turbine Building	O.P.+ 2,655 mm (9 mm increase since 16:00 on September 6)	O.P.+ 3,220 mm (29 mm decrease since 16:00 on September 6)	O.P.+ 3,222 mm (39 mm increase since 16:00 on September 6)	O.P.+ 2,840 mm (27 mm decrease since 16:00 on September 6)
	Water level of Reactor Building	O.P.+ 4,619 mm (43 mm increase since 16:00 on September 6)	O.P.+ 3,455 mm (36 mm decrease since 16:00 on September 6)	O.P.+ 3,363 mm (40 mm increase since 16:00 on September 6)	O.P.+ 2,865 mm (27 mm decrease since 16:00 on September 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,811 mm (Increase from initial level:5,028 mm, 2 mm increase since 16:00 on September 6) O.P.+ 3,271 mm (Increase from initial level:3,997 mm, 113 mm increase since 16:00 on September 6) O.P.+ 4,336 mm (Water level from floor:540 mm, 1 mm increase since 16:00 on September 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 17:10 on September 5 to 8:44 on September 7)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:19 on September 6)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:51 on September 6   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- From 5:17 AM on September 6 to 8:20 AM on September 7, the accumulated water was transferred from the Common Pool Duct to the Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building).				

For quick publication of the data of water level, values are provided as reference values.