

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 7)**

Water Level of the accumulated water (at 16:00 on September 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,221 mm (24 mm increase since 7:00 on September 7)	O.P.+ 3,162 mm (3 mm increase since 7:00 on September 7)	—
	Water level of Turbine Building	O.P.+ 2,661 mm (6 mm increase since 7:00 on September 7)	O.P.+ 3,242 mm (22 mm increase since 7:00 on September 7)	O.P.+ 3,207 mm (15 mm decrease since 7:00 on September 7)	O.P.+ 2,827 mm (13 mm decrease since 7:00 on September 7)
	Water level of Reactor Building	O.P.+ 4,604 mm (15 mm decrease since 7:00 on September 7)	O.P.+ 3,459 mm (4 mm increase since 7:00 on September 7)	O.P.+ 3,355 mm (8 mm decrease since 7:00 on September 7)	O.P.+ 2,852 mm (13 mm decrease since 7:00 on September 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,814 mm (Increase from initial level:5,031 mm, 3 mm increase since 7:00 on September 7) O.P.+ 3,282 mm (Increase from initial level:4,008 mm, 11 mm increase since 7:00 on September 7) O.P.+ 4,339 mm (Water level from floor:543 mm, 3 mm increase since 7:00 on September 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:19 on September 6)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:51 on September 6   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.