

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 10)**

Water Level of the accumulated water (at 16:00 on September 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,254 mm (20 mm decrease since 7:00 on September 10)	O.P.+ 3,139 mm (13 mm increase since 7:00 on September 10)	—
	Water level of Turbine Building	O.P.+ 2,707 mm (6 mm increase since 7:00 on September 10)	O.P.+ 3,271 mm (17 mm decrease since 7:00 on September 10)	O.P.+ 3,215 mm (18 mm increase since 7:00 on September 10)	O.P.+ 2,737 mm (5 mm decrease since 7:00 on September 10)
	Water level of Reactor Building	O.P.+ 4,578 mm (17 mm decrease since 7:00 on September 10)	O.P.+ 3,510 mm (16 mm decrease since 7:00 on September 10)	O.P.+ 3,356 mm (21 mm increase since 7:00 on September 10)	O.P.+ 2,763 mm (10 mm decrease since 7:00 on September 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,830 mm (Increase from initial level:5,047 mm, 2 mm increase since 7:00 on September 10) O.P.+ 3,297 mm (Increase from initial level:4,023 mm, 8 mm decrease since 7:00 on September 10) O.P.+ 4,350 mm (Water level from floor:554 mm, 1 mm increase since 7:00 on September 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 8:23 on September 9)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on September 9)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:51 on September 6   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.