

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 11)**

Water Level of the accumulated water (at 7:00 on September 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,220 mm (34 mm decrease since 16:00 on September 10)	O.P.+ 3,160 mm (21 mm increase since 16:00 on September 10)	—
	Water level of Turbine Building	O.P.+ 2,717 mm (10 mm increase since 16:00 on September 10)	O.P.+ 3,241 mm (30 mm decrease since 16:00 on September 10)	O.P.+ 3,242 mm (27 mm increase since 16:00 on September 10)	O.P.+ 2,736 mm (1 mm decrease since 16:00 on September 10)
	Water level of Reactor Building	O.P.+ 4,571 mm (7 mm decrease since 16:00 on September 10)	O.P.+ 3,480 mm (30 mm decrease since 16:00 on September 10)	O.P.+ 3,386 mm (30 mm increase since 16:00 on September 10)	O.P.+ 2,763 mm (No change since 16:00 on September 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,834 mm (Increase from initial level:5,051 mm, 4 mm increase since 16:00 on September 10) O.P.+ 3,209 mm (Increase from initial level:3,935 mm, 88 mm decrease since 16:00 on September 10) O.P.+ 4,352 mm (Water level from floor:556 mm, 2 mm increase since 16:00 on September 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 8:23 on September 9)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on September 9)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:51 on September 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.