

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 11)**

Water Level of the accumulated water (at 16:00 on September 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,200 mm (20 mm decrease since 7:00 on September 11)	O.P.+ 3,167 mm (7 mm increase since 7:00 on September 11)	—
	Water level of Turbine Building	O.P.+ 2,723 mm (6 mm increase since 7:00 on September 11)	O.P.+ 3,224 mm (17 mm decrease since 7:00 on September 11)	O.P.+ 3,238 mm (4 mm decrease since 7:00 on September 11)	O.P.+ 2,736 mm (No change since 7:00 on September 11)
	Water level of Reactor Building	O.P.+ 4,552 mm (19 mm decrease since 7:00 on September 11)	O.P.+ 3,464 mm (16 mm decrease since 7:00 on September 11)	O.P.+ 3,389 mm (3 mm increase since 7:00 on September 11)	O.P.+ 2,761 mm (2 mm decrease since 7:00 on September 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,835 mm (Increase from initial level:5,052 mm, 1 mm increase since 7:00 on September 11) O.P.+ 3,302 mm (Increase from initial level:4,028 mm, 93 mm increase since 7:00 on September 11) O.P.+ 4,354 mm (Water level from floor:558 mm, 2 mm increase since 7:00 on September 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 8:23 on September 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on September 11)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on September 9)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:51 on September 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.