

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 12)**

Water Level of the accumulated water (at 7:00 on September 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,168 mm (32 mm decrease since 16:00 on September 11)	O.P.+ 3,159 mm (8 mm decrease since 16:00 on September 11)	—
	Water level of Turbine Building	O.P.+ 2,731 mm (8 mm increase since 16:00 on September 11)	O.P.+ 3,195 mm (29 mm decrease since 16:00 on September 11)	O.P.+ 3,219 mm (19 mm decrease since 16:00 on September 11)	O.P.+ 2,737 mm (1 mm increase since 16:00 on September 11)
	Water level of Reactor Building	O.P.+ 4,544 mm (8 mm decrease since 16:00 on September 11)	O.P.+ 3,435 mm (29 mm decrease since 16:00 on September 11)	O.P.+ 3,369 mm (20 mm decrease since 16:00 on September 11)	O.P.+ 2,761 mm (No change since 16:00 on September 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,838 mm (Increase from initial level:5,055 mm, 3 mm increase since 16:00 on September 11) O.P.+ 3,604 mm (Increase from initial level:4,330 mm, 302 mm increase since 16:00 on September 11) O.P.+ 4,356 mm (Water level from floor:560 mm, 2 mm increase since 16:00 on September 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 8:23 on September 9 to 8:17 on September 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on September 11)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (From 14:00 on September 9 to 8:13 on September 12)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:30 on September 12   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	– At 7:30 AM on September 12, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.