

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 12)**

Water Level of the accumulated water (at 16:00 on September 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,195 mm (27 mm increase since 7:00 on September 12)	O.P.+ 3,140 mm (19 mm decrease since 7:00 on September 12)	—
	Water level of Turbine Building	O.P.+ 2,736 mm (5 mm increase since 7:00 on September 12)	O.P.+ 3,219 mm (24 mm increase since 7:00 on September 12)	O.P.+ 3,171 mm (48 mm decrease since 7:00 on September 12)	O.P.+ 2,765 mm (28 mm increase since 7:00 on September 12)
	Water level of Reactor Building	O.P.+ 4,532 mm (12 mm decrease since 7:00 on September 12)	O.P.+ 3,443 mm (8 mm increase since 7:00 on September 12)	O.P.+ 3,330 mm (39 mm decrease since 7:00 on September 12)	O.P.+ 2,778 mm (17 mm increase since 7:00 on September 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,840 mm (Increase from initial level:5,057 mm, 2 mm increase since 7:00 on September 12) O.P.+ 3,789 mm (Increase from initial level:4,515 mm, 185 mm increase since 7:00 on September 12) O.P.+ 4,356 mm (Water level from floor:560 mm, No change since 7:00 on September 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on September 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:57 on September 12   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:30 AM on September 12, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. After the filter cleaning, the apparatus was restarted at 11:57 AM on the same day.				

For quick publication of the data of water level, values are provided as reference values.