

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 13)**

Water Level of the accumulated water (at 7:00 on September 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,242 mm (47 mm increase since 16:00 on September 12)	O.P.+ 3,092 mm (48 mm decrease since 16:00 on September 12)	—
	Water level of Turbine Building	O.P.+ 2,745 mm (9 mm increase since 16:00 on September 12)	O.P.+ 3,260 mm (41 mm increase since 16:00 on September 12)	O.P.+ 3,095 mm (76 mm decrease since 16:00 on September 12)	O.P.+ 2,810 mm (45 mm increase since 16:00 on September 12)
	Water level of Reactor Building	O.P.+ 4,541 mm (9 mm increase since 16:00 on September 12)	O.P.+ 3,482 mm (39 mm increase since 16:00 on September 12)	O.P.+ 3,250 mm (80 mm decrease since 16:00 on September 12)	O.P.+ 2,817 mm (39 mm increase since 16:00 on September 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,843 mm (Increase from initial level:5,060 mm, 3 mm increase since 16:00 on September 12) O.P.+ 3,568 mm (Increase from initial level:4,294 mm, 221 mm decrease since 16:00 on September 12) O.P.+ 4,357 mm (Water level from floor:561 mm, 1 mm increase since 16:00 on September 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on September 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:57 on September 12   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.