

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 13)**

Water Level of the accumulated water (at 16:00 on September 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,266 mm (24 mm increase since 7:00 on September 13)	O.P.+ 3,061 mm (31 mm decrease since 7:00 on September 13)	—
	Water level of Turbine Building	O.P.+ 2,750 mm (5 mm increase since 7:00 on September 13)	O.P.+ 3,282 mm (22 mm increase since 7:00 on September 13)	O.P.+ 3,056 mm (39 mm decrease since 7:00 on September 13)	O.P.+ 2,833 mm (23 mm increase since 7:00 on September 13)
	Water level of Reactor Building	O.P.+ 4,536 mm (5 mm decrease since 7:00 on September 13)	O.P.+ 3,504 mm (22 mm increase since 7:00 on September 13)	O.P.+ 3,205 mm (45 mm decrease since 7:00 on September 13)	O.P.+ 2,838 mm (21 mm increase since 7:00 on September 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,845 mm (Increase from initial level:5,062 mm, 2 mm increase since 7:00 on September 13) O.P.+ 3,452 mm (Increase from initial level:4,178 mm, 116 mm decrease since 7:00 on September 13) O.P.+ 4,358 mm (Water level from floor:562 mm, 1 mm increase since 7:00 on September 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on September 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:57 on September 12   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.