

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 14)**

Water Level of the accumulated water (at 7:00 on September 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,305 mm (39 mm increase since 16:00 on September 13)	O.P.+ 3,015 mm (46 mm decrease since 16:00 on September 13)	—
	Water level of Turbine Building	O.P.+ 2,758 mm (8 mm increase since 16:00 on September 13)	O.P.+ 3,316 mm (34 mm increase since 16:00 on September 13)	O.P.+ 2,994 mm (62 mm decrease since 16:00 on September 13)	O.P.+ 2,864 mm (31 mm increase since 16:00 on September 13)
	Water level of Reactor Building	O.P.+ 4,543 mm (7 mm increase since 16:00 on September 13)	O.P.+ 3,537 mm (33 mm increase since 16:00 on September 13)	* Data missing.	O.P.+ 2,866 mm (28 mm increase since 16:00 on September 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,848 mm (Increase from initial level:5,065 mm, 3 mm increase since 16:00 on September 13) O.P.+ 3,252 mm (Increase from initial level:3,978 mm, 200 mm decrease since 16:00 on September 13) O.P.+ 4,360 mm (Water level from floor:564 mm, 2 mm increase since 16:00 on September 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on September 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:57 on September 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- The data at 7:00 AM on September 14, 2012 was missing due to the water gauge camera failure.				

For quick publication of the data of water level, values are provided as reference values.