

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 14)**

Water Level of the accumulated water (at 16:00 on September 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,295 mm (10 mm decrease since 7:00 on September 14)	O.P.+ 3,007 mm (8 mm decrease since 7:00 on September 14)	—
	Water level of Turbine Building	O.P.+ 2,763 mm (5 mm increase since 7:00 on September 14)	O.P.+ 3,307 mm (9 mm decrease since 7:00 on September 14)	O.P.+ 3,009 mm (15 mm increase since 7:00 on September 14)	O.P.+ 2,862 mm (2 mm decrease since 7:00 on September 14)
	Water level of Reactor Building	O.P.+ 4,533 mm (10 mm decrease since 7:00 on September 14)	O.P.+ 3,541 mm (4 mm increase since 7:00 on September 14)	O.P.+ 3,141 mm (64 mm decrease since 7:00 on September 14)	O.P.+ 2,876 mm (10 mm increase since 7:00 on September 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,850 mm (Increase from initial level:5,067 mm, 2 mm increase since 7:00 on September 14) O.P.+ 3,191 mm (Increase from initial level:3,917 mm, 61 mm decrease since 7:00 on September 14) O.P.+ 4,361 mm (Water level from floor:565 mm, 1 mm increase since 7:00 on September 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:29 on September 14)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:22 on September 11 to 10:54 on September 14)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:45 on September 14)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:57 on September 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since the data at 7:00 AM on September 14, 2012 was missing due to the water gauge camera failure, the data of the water level of Unit 3 reactor building is compared with the data at 4:00 PM on September 13.				

For quick publication of the data of water level, values are provided as reference values.