

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 18)**

Water Level of the accumulated water (at 7:00 on September 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,200 mm (46 mm increase since 16:00 on September 17)	O.P.+ 3,123 mm (20 mm decrease since 16:00 on September 17)	—
	Water level of Turbine Building	O.P.+ 2,806 mm (7 mm increase since 16:00 on September 17)	O.P.+ 3,225 mm (42 mm increase since 16:00 on September 17)	O.P.+ 3,153 mm (31 mm decrease since 16:00 on September 17)	O.P.+ 2,787 mm (9 mm decrease since 16:00 on September 17)
	Water level of Reactor Building	O.P.+ 4,433 mm (No change since 16:00 on September 17)	O.P.+ 3,449 mm (39 mm increase since 16:00 on September 17)	O.P.+ 3,307 mm (31 mm decrease since 16:00 on September 17)	O.P.+ 2,805 mm (8 mm decrease since 16:00 on September 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,857 mm (Increase from initial level:5,074 mm, 1 mm increase since 16:00 on September 17) O.P.+ 2,715 mm (Increase from initial level:3,441 mm, 62 mm decrease since 16:00 on September 17) O.P.+ 4,384 mm (Water level from floor:588 mm, 3 mm increase since 16:00 on September 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:45 on September 14)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): From 11:57 on September 12 to 8:25 on September 18 Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:25 AM on September 18, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.