

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 19)**

Water Level of the accumulated water (at 7:00 on September 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,264 mm (38 mm increase since 16:00 on September 18)	O.P.+ 3,089 mm (21 mm decrease since 16:00 on September 18)	—
	Water level of Turbine Building	O.P.+ 2,817 mm (7 mm increase since 16:00 on September 18)	O.P.+ 3,281 mm (34 mm increase since 16:00 on September 18)	O.P.+ 3,112 mm (25 mm decrease since 16:00 on September 18)	O.P.+ 2,771 mm (10 mm decrease since 16:00 on September 18)
	Water level of Reactor Building	O.P.+ 4,433 mm (7 mm increase since 16:00 on September 18)	O.P.+ 3,506 mm (33 mm increase since 16:00 on September 18)	O.P.+ 3,264 mm (26 mm decrease since 16:00 on September 18)	O.P.+ 2,790 mm (11 mm decrease since 16:00 on September 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,794 mm (Increase from initial level:5,011 mm, 63 mm decrease since 16:00 on September 18) O.P.+ 2,852 mm (Increase from initial level:3,578 mm, 55 mm increase since 16:00 on September 18) O.P.+ 4,391 mm (Water level from floor:595 mm, 4 mm increase since 16:00 on September 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:01 on September 18)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:26 on September 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.