

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 20)**

Water Level of the accumulated water (at 7:00 on September 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,214 mm (40 mm decrease since 16:00 on September 19)	O.P.+ 3,107 mm (23 mm increase since 16:00 on September 19)	—
	Water level of Turbine Building	O.P.+ 2,828 mm (7 mm increase since 16:00 on September 19)	O.P.+ 3,236 mm (37 mm decrease since 16:00 on September 19)	O.P.+ 3,164 mm (40 mm increase since 16:00 on September 19)	O.P.+ 2,752 mm (10 mm decrease since 16:00 on September 19)
	Water level of Reactor Building	O.P.+ 4,464 mm (27 mm increase since 16:00 on September 19)	O.P.+ 3,478 mm (34 mm decrease since 16:00 on September 19)	O.P.+ 3,309 mm (42 mm increase since 16:00 on September 19)	O.P.+ 2,773 mm (12 mm decrease since 16:00 on September 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,698 mm (Increase from initial level:4,915 mm, 61 mm decrease since 16:00 on September 19) O.P.+ 2,955 mm (Increase from initial level:3,681 mm, 60 mm increase since 16:00 on September 19) O.P.+ 4,397 mm (Water level from floor:601 mm, 4 mm increase since 16:00 on September 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:40 on September 19)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:01 on September 18)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:26 on September 18   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.