

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 20)**

Water Level of the accumulated water (at 16:00 on September 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,192 mm (22 mm decrease since 7:00 on September 20)	O.P.+ 3,120 mm (13 mm increase since 7:00 on September 20)	—
	Water level of Turbine Building	O.P.+ 2,831 mm (3 mm increase since 7:00 on September 20)	O.P.+ 3,217 mm (19 mm decrease since 7:00 on September 20)	O.P.+ 3,183 mm (19 mm increase since 7:00 on September 20)	O.P.+ 2,747 mm (5 mm decrease since 7:00 on September 20)
	Water level of Reactor Building	O.P.+ 4,461 mm (3 mm decrease since 7:00 on September 20)	O.P.+ 3,458 mm (20 mm decrease since 7:00 on September 20)	O.P.+ 3,330 mm (21 mm increase since 7:00 on September 20)	O.P.+ 2,768 mm (5 mm decrease since 7:00 on September 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,663 mm (Increase from initial level:4,880 mm, 35 mm decrease since 7:00 on September 20) O.P.+ 3,001 mm (Increase from initial level:3,727 mm, 46 mm increase since 7:00 on September 20) O.P.+ 4,399 mm (Water level from floor:603 mm, 2 mm increase since 7:00 on September 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:40 on September 19)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:01 on September 18)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:26 on September 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.