

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 21)**

Water Level of the accumulated water (at 7:00 on September 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,155 mm (37 mm decrease since 16:00 on September 20)	O.P.+ 3,144 mm (24 mm increase since 16:00 on September 20)	—
	Water level of Turbine Building	O.P.+ 2,838 mm (7 mm increase since 16:00 on September 20)	O.P.+ 3,185 mm (32 mm decrease since 16:00 on September 20)	O.P.+ 3,214 mm (31 mm increase since 16:00 on September 20)	O.P.+ 2,740 mm (7 mm decrease since 16:00 on September 20)
	Water level of Reactor Building	O.P.+ 4,459 mm (2 mm decrease since 16:00 on September 20)	O.P.+ 3,425 mm (33 mm decrease since 16:00 on September 20)	O.P.+ 3,364 mm (34 mm increase since 16:00 on September 20)	O.P.+ 2,762 mm (6 mm decrease since 16:00 on September 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,603 mm (Increase from initial level:4,820 mm, 60 mm decrease since 16:00 on September 20) O.P.+ 3,062 mm (Increase from initial level:3,788 mm, 61 mm increase since 16:00 on September 20) O.P.+ 4,402 mm (Water level from floor:606 mm, 3 mm increase since 16:00 on September 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:40 on September 19)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:01 on September 18)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:26 on September 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.