

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 21)**

Water Level of the accumulated water (at 16:00 on September 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,135 mm (20 mm decrease since 7:00 on September 21)	O.P.+ 3,157 mm (13 mm increase since 7:00 on September 21)	—
	Water level of Turbine Building	O.P.+ 2,842 mm (4 mm increase since 7:00 on September 21)	O.P.+ 3,167 mm (18 mm decrease since 7:00 on September 21)	O.P.+ 3,231 mm (17 mm increase since 7:00 on September 21)	O.P.+ 2,737 mm (3 mm decrease since 7:00 on September 21)
	Water level of Reactor Building	O.P.+ 4,457 mm (2 mm decrease since 7:00 on September 21)	O.P.+ 3,410 mm (15 mm decrease since 7:00 on September 21)	O.P.+ 3,382 mm (18 mm increase since 7:00 on September 21)	O.P.+ 2,758 mm (4 mm decrease since 7:00 on September 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,568 mm (Increase from initial level:4,785 mm, 35 mm decrease since 7:00 on September 21) O.P.+ 3,108 mm (Increase from initial level:3,834 mm, 46 mm increase since 7:00 on September 21) O.P.+ 4,405 mm (Water level from floor:609 mm, 3 mm increase since 7:00 on September 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:40 on September 19)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:01 on September 18)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:26 on September 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.