

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 24)**

| | | | | | |
|---|--|---|--|--|--|
| Water Level of the accumulated water (at 7:00 on September 24) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,242 mm (50 mm increase since 16:00 on September 23) | O.P.+ 3,173 mm (2 mm increase since 16:00 on September 23) | — |
| | Water level of Turbine Building | O.P.+ 2,875 mm (11 mm increase since 16:00 on September 23) | O.P.+ 3,261 mm (45 mm increase since 16:00 on September 23) | O.P.+ 3,195 mm (9 mm decrease since 16:00 on September 23) | O.P.+ 2,882 mm (48 mm increase since 16:00 on September 23) |
| | Water level of Reactor Building | O.P.+ 4,630 mm (145 mm increase since 16:00 on September 23) | O.P.+ 3,489 mm (25 mm increase since 16:00 on September 23) | O.P.+ 3,354 mm (19 mm decrease since 16:00 on September 23) | O.P.+ 2,863 mm (38 mm increase since 16:00 on September 23) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 2,910 mm (Increase from initial level:4,127 mm, 168 mm decrease since 16:00 on September 23) O.P.+ 3,366 mm (Increase from initial level:4,092 mm, 63 mm increase since 16:00 on September 23) O.P.+ 4,417 mm (Water level from floor:621 mm, 2 mm increase since 16:00 on September 23) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | — | — | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:29 on September 24 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | - At 7:29 AM on September 24, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. | | | | |

For quick publication of the data of water level, values are provided as reference values.