

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 24)**

Water Level of the accumulated water (at 16:00 on September 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,233 mm (9 mm decrease since 7:00 on September 24)	O.P.+ 3,174 mm (1 mm increase since 7:00 on September 24)	—
	Water level of Turbine Building	O.P.+ 2,885 mm (10 mm increase since 7:00 on September 24)	O.P.+ 3,254 mm (7 mm decrease since 7:00 on September 24)	O.P.+ 3,189 mm (6 mm decrease since 7:00 on September 24)	O.P.+ 2,907 mm (25 mm increase since 7:00 on September 24)
	Water level of Reactor Building	O.P.+ 4,681 mm (51 mm increase since 7:00 on September 24)	O.P.+ 3,498 mm (9 mm increase since 7:00 on September 24)	O.P.+ 3,345 mm (9 mm decrease since 7:00 on September 24)	O.P.+ 2,880 mm (17 mm increase since 7:00 on September 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,952 mm (Increase from initial level:4,169 mm, 42 mm increase since 7:00 on September 24) O.P.+ 3,311 mm (Increase from initial level:4,037 mm, 55 mm decrease since 7:00 on September 24) O.P.+ 4,418 mm (Water level from floor:622 mm, 1 mm increase since 7:00 on September 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:26 on September 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:59 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:32 on September 24   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:29 AM on September 24, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning. At 1:04 PM on the same day, the apparatus was restarted after the filter cleaning was completed and the steady flow rate was achieved at 1:32 PM.				

For quick publication of the data of water level, values are provided as reference values.