

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 25)**

Water Level of the accumulated water (at 7:00 on September 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,200 mm (33 mm decrease since 16:00 on September 24)	O.P.+ 3,181 mm (7 mm increase since 16:00 on September 24)	—
	Water level of Turbine Building	O.P.+ 2,900 mm (15 mm increase since 16:00 on September 24)	O.P.+ 3,224 mm (30 mm decrease since 16:00 on September 24)	O.P.+ 3,192 mm (3 mm increase since 16:00 on September 24)	O.P.+ 2,947 mm (40 mm increase since 16:00 on September 24)
	Water level of Reactor Building	O.P.+ 4,751 mm (70 mm increase since 16:00 on September 24)	O.P.+ 3,463 mm (35 mm decrease since 16:00 on September 24)	O.P.+ 3,347 mm (2 mm increase since 16:00 on September 24)	O.P.+ 2,915 mm (35 mm increase since 16:00 on September 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,071 mm (Increase from initial level:4,288 mm, 119 mm increase since 16:00 on September 24) O.P.+ 2,764 mm (Increase from initial level:3,490 mm, 547 mm decrease since 16:00 on September 24) O.P.+ 4,418 mm (Water level from floor:622 mm, No change since 16:00 on September 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:26 on September 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:59 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:32 on September 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.