

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 25)**

Water Level of the accumulated water (at 16:00 on September 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,180 mm (20 mm decrease since 7:00 on September 25)	O.P.+ 3,185 mm (4 mm increase since 7:00 on September 25)	—
	Water level of Turbine Building	O.P.+ 2,907 mm (7 mm increase since 7:00 on September 25)	O.P.+ 3,207 mm (17 mm decrease since 7:00 on September 25)	O.P.+ 3,193 mm (1 mm increase since 7:00 on September 25)	O.P.+ 2,967 mm (20 mm increase since 7:00 on September 25)
	Water level of Reactor Building	O.P.+ 4,770 mm (19 mm increase since 7:00 on September 25)	O.P.+ 3,447 mm (16 mm decrease since 7:00 on September 25)	O.P.+ 3,347 mm (No change since 7:00 on September 25)	O.P.+ 2,931 mm (16 mm increase since 7:00 on September 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,084 mm (Increase from initial level:4,301 mm, 13 mm increase since 7:00 on September 25) O.P.+ 2,627 mm (Increase from initial level:3,353 mm, 137 mm decrease since 7:00 on September 25) O.P.+ 4,419 mm (Water level from floor:623 mm, 1 mm increase since 7:00 on September 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:26 on September 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:59 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:03 on September 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:59 on September 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- We started the Cesium Adsorption Apparatus at 11:03 on September 25 based on the situation of the water level at the Turbine Building etc.in order to conduct the inspection to confirm the soundness of pipes etc. of 2nd Cesium Adsorption Apparatus (Sarry). We stopped Sarry at 12:59 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.