

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 26)**

Water Level of the accumulated water (at 7:00 on September 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,148 mm (32 mm decrease since 16:00 on September 25)	O.P.+ 3,190 mm (5 mm increase since 16:00 on September 25)	—
	Water level of Turbine Building	O.P.+ 2,922 mm (15 mm increase since 16:00 on September 25)	O.P.+ 3,178 mm (29 mm decrease since 16:00 on September 25)	O.P.+ 3,192 mm (1 mm decrease since 16:00 on September 25)	O.P.+ 2,999 mm (32 mm increase since 16:00 on September 25)
	Water level of Reactor Building	O.P.+ 4,777 mm (7 mm increase since 16:00 on September 25)	O.P.+ 3,420 mm (27 mm decrease since 16:00 on September 25)	O.P.+ 3,347 mm (No change since 16:00 on September 25)	O.P.+ 2,958 mm (27 mm increase since 16:00 on September 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,023 mm (Increase from initial level:4,240 mm, 61 mm decrease since 16:00 on September 25) O.P.+ 2,690 mm (Increase from initial level:3,416 mm, 63 mm increase since 16:00 on September 25) O.P.+ 4,420 mm (Water level from floor:624 mm, 1 mm increase since 16:00 on September 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:26 on September 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:59 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:03 on September 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:59 on September 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.