

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 26)**

Water Level of the accumulated water (at 16:00 on September 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,132 mm (16 mm decrease since 7:00 on September 26)	O.P.+ 3,195 mm (5 mm increase since 7:00 on September 26)	—
	Water level of Turbine Building	O.P.+ 2,931 mm (9 mm increase since 7:00 on September 26)	O.P.+ 3,163 mm (15 mm decrease since 7:00 on September 26)	O.P.+ 3,193 mm (1 mm increase since 7:00 on September 26)	O.P.+ 3,017 mm (18 mm increase since 7:00 on September 26)
	Water level of Reactor Building	O.P.+ 4,753 mm (24 mm decrease since 7:00 on September 26)	O.P.+ 3,406 mm (14 mm decrease since 7:00 on September 26)	O.P.+ 3,349 mm (2 mm increase since 7:00 on September 26)	O.P.+ 2,974 mm (16 mm increase since 7:00 on September 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,989 mm (Increase from initial level:4,206 mm, 34 mm decrease since 7:00 on September 26) O.P.+ 2,726 mm (Increase from initial level:3,452 mm, 36 mm increase since 7:00 on September 26) O.P.+ 4,420 mm (Water level from floor:624 mm, No change since 7:00 on September 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:26 on September 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:59 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:03 on September 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:59 on September 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.