

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 27)**

Water Level of the accumulated water (at 7:00 on September 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,101 mm (31 mm decrease since 16:00 on September 26)	O.P.+ 3,202 mm (7 mm increase since 16:00 on September 26)	—
	Water level of Turbine Building	O.P.+ 2,946 mm (15 mm increase since 16:00 on September 26)	O.P.+ 3,136 mm (27 mm decrease since 16:00 on September 26)	O.P.+ 3,196 mm (3 mm increase since 16:00 on September 26)	O.P.+ 3,046 mm (29 mm increase since 16:00 on September 26)
	Water level of Reactor Building	O.P.+ 4,730 mm (23 mm decrease since 16:00 on September 26)	O.P.+ 3,382 mm (24 mm decrease since 16:00 on September 26)	O.P.+ 3,351 mm (2 mm increase since 16:00 on September 26)	O.P.+ 3,000 mm (26 mm increase since 16:00 on September 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,930 mm (Increase from initial level:4,147 mm, 59 mm decrease since 16:00 on September 26) O.P.+ 2,779 mm (Increase from initial level:3,505 mm, 53 mm increase since 16:00 on September 26) O.P.+ 4,421 mm (Water level from floor:625 mm, 1 mm increase since 16:00 on September 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:26 on September 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:59 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:03 on September 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:59 on September 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.