

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 28)**

Water Level of the accumulated water (at 7:00 on September 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,171 mm (51 mm increase since 16:00 on September 27)	O.P.+ 3,151 mm (41 mm decrease since 16:00 on September 27)	—
	Water level of Turbine Building	O.P.+ 2,968 mm (14 mm increase since 16:00 on September 27)	O.P.+ 3,198 mm (44 mm increase since 16:00 on September 27)	O.P.+ 3,118 mm (53 mm decrease since 16:00 on September 27)	O.P.+ 3,082 mm (21 mm increase since 16:00 on September 27)
	Water level of Reactor Building	O.P.+ 4,690 mm (19 mm decrease since 16:00 on September 27)	O.P.+ 3,428 mm (45 mm increase since 16:00 on September 27)	O.P.+ 3,281 mm (54 mm decrease since 16:00 on September 27)	O.P.+ 3,040 mm (25 mm increase since 16:00 on September 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,840 mm (Increase from initial level:4,057 mm, 56 mm decrease since 16:00 on September 27) O.P.+ 2,876 mm (Increase from initial level:3,602 mm, 58 mm increase since 16:00 on September 27) O.P.+ 4,423 mm (Water level from floor:627 mm, 1 mm increase since 16:00 on September 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:59 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:03 on September 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:59 on September 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.