

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 28)**

Water Level of the accumulated water (at 16:00 on September 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,202 mm (31 mm increase since 7:00 on September 28)	O.P.+ 3,140 mm (11 mm decrease since 7:00 on September 28)	—
	Water level of Turbine Building	O.P.+ 2,978 mm (10 mm increase since 7:00 on September 28)	O.P.+ 3,225 mm (27 mm increase since 7:00 on September 28)	O.P.+ 3,104 mm (14 mm decrease since 7:00 on September 28)	O.P.+ 3,069 mm (13 mm decrease since 7:00 on September 28)
	Water level of Reactor Building	O.P.+ 4,742 mm (52 mm increase since 7:00 on September 28)	O.P.+ 3,472 mm (44 mm increase since 7:00 on September 28)	O.P.+ 3,270 mm (11 mm decrease since 7:00 on September 28)	O.P.+ 3,063 mm (23 mm increase since 7:00 on September 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,857 mm (Increase from initial level:4,074 mm, 17 mm increase since 7:00 on September 28) O.P.+ 2,920 mm (Increase from initial level:3,646 mm, 44 mm increase since 7:00 on September 28) O.P.+ 4,423 mm (Water level from floor:627 mm, No change since 7:00 on September 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:59 on September 24)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:20 on September 28)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:03 on September 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:59 on September 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.