

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 1)**

Water Level of the accumulated water (at 16:00 on October 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,202 mm (13 mm decrease since 7:00 on October 1)	O.P.+ 3,127 mm (12 mm increase since 7:00 on October 1)	—
	Water level of Turbine Building	O.P.+ 2,748 mm (11 mm increase since 7:00 on October 1)	O.P.+ 3,226 mm (13 mm decrease since 7:00 on October 1)	O.P.+ 3,132 mm (27 mm increase since 7:00 on October 1)	O.P.+ 2,938 mm (13 mm decrease since 7:00 on October 1)
	Water level of Reactor Building	O.P.+ 4,921 mm (2 mm decrease since 7:00 on October 1)	O.P.+ 3,475 mm (19 mm decrease since 7:00 on October 1)	O.P.+ 3,282 mm (22 mm increase since 7:00 on October 1)	O.P.+ 2,947 mm (13 mm decrease since 7:00 on October 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,203 mm (Increase from initial level:4,420 mm, 2 mm increase since 7:00 on October 1) O.P.+ 3,255 mm (Increase from initial level:3,981 mm, 50 mm increase since 7:00 on October 1) O.P.+ 4,431 mm (Water level from floor:635 mm, 1 mm increase since 7:00 on October 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on September 29)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 9:59 on September 24 to 9:50 on October 1)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:20 on September 28)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:03 on September 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:59 on September 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.