

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 2)**

Water Level of the accumulated water (at 7:00 on October 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,174 mm (28 mm decrease since 16:00 on October 1)	O.P.+ 3,167 mm (40 mm increase since 16:00 on October 1)	—
	Water level of Turbine Building	O.P.+ 2,763 mm (15 mm increase since 16:00 on October 1)	O.P.+ 3,203 mm (23 mm decrease since 16:00 on October 1)	O.P.+ 3,184 mm (52 mm increase since 16:00 on October 1)	O.P.+ 2,919 mm (19 mm decrease since 16:00 on October 1)
	Water level of Reactor Building	O.P.+ 4,900 mm (21 mm decrease since 16:00 on October 1)	O.P.+ 3,451 mm (24 mm decrease since 16:00 on October 1)	O.P.+ 3,336 mm (54 mm increase since 16:00 on October 1)	O.P.+ 2,930 mm (17 mm decrease since 16:00 on October 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,166 mm (Increase from initial level:4,383 mm, 37 mm decrease since 16:00 on October 1) O.P.+ 3,325 mm (Increase from initial level:4,051 mm, 70 mm increase since 16:00 on October 1) O.P.+ 4,433 mm (Water level from floor:637 mm, 2 mm increase since 16:00 on October 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on September 29)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:20 on September 28)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:03 on September 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:59 on September 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.