

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 2)**

Water Level of the accumulated water (at 16:00 on October 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,195 mm (21 mm increase since 7:00 on October 2)	O.P.+ 3,181 mm (14 mm increase since 7:00 on October 2)	—
	Water level of Turbine Building	O.P.+ 2,774 mm (11 mm increase since 7:00 on October 2)	O.P.+ 3,219 mm (16 mm increase since 7:00 on October 2)	O.P.+ 3,182 mm (2 mm decrease since 7:00 on October 2)	O.P.+ 2,909 mm (10 mm decrease since 7:00 on October 2)
	Water level of Reactor Building	O.P.+ 4,877 mm (23 mm decrease since 7:00 on October 2)	O.P.+ 3,450 mm (1 mm decrease since 7:00 on October 2)	O.P.+ 3,343 mm (7 mm increase since 7:00 on October 2)	O.P.+ 2,922 mm (8 mm decrease since 7:00 on October 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,145 mm (Increase from initial level:4,362 mm, 21 mm decrease since 7:00 on October 2) O.P.+ 3,368 mm (Increase from initial level:4,094 mm, 43 mm increase since 7:00 on October 2) O.P.+ 4,436 mm (Water level from floor:640 mm, 3 mm increase since 7:00 on October 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 10:05 on September 29 to 10:12 on October 2)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:20 on September 28)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:03 on September 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:59 on September 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.