

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 3)**

Water Level of the accumulated water (at 7:00 on October 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,246 mm (51 mm increase since 16:00 on October 2)	O.P.+ 3,169 mm (12 mm decrease since 16:00 on October 2)	—
	Water level of Turbine Building	O.P.+ 2,789 mm (15 mm increase since 16:00 on October 2)	O.P.+ 3,264 mm (45 mm increase since 16:00 on October 2)	O.P.+ 3,164 mm (18 mm decrease since 16:00 on October 2)	O.P.+ 2,894 mm (15 mm decrease since 16:00 on October 2)
	Water level of Reactor Building	O.P.+ 4,849 mm (28 mm decrease since 16:00 on October 2)	O.P.+ 3,492 mm (42 mm increase since 16:00 on October 2)	O.P.+ 3,326 mm (17 mm decrease since 16:00 on October 2)	O.P.+ 2,907 mm (15 mm decrease since 16:00 on October 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,110 mm (Increase from initial level:4,327 mm, 35 mm decrease since 16:00 on October 2) O.P.+ 3,434 mm (Increase from initial level:4,160 mm, 66 mm increase since 16:00 on October 2) O.P.+ 4,436 mm (Water level from floor:640 mm, No change since 16:00 on October 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:20 on September 28)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:59 on September 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 9:00 AM on October 3, the Cesium Adsorption Apparatus was stopped in order to switch to a different power source. Since the 2nd Cesium Adsorption Apparatus (Sarry) will be started on October 4, the suspension period will be short, and there will be no problem.				

For quick publication of the data of water level, values are provided as reference values.