

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 3)**

Water Level of the accumulated water (at 16:00 on October 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,275 mm (29 mm increase since 7:00 on October 3)	O.P.+ 3,163 mm (6 mm decrease since 7:00 on October 3)	—
	Water level of Turbine Building	O.P.+ 2,800 mm (11 mm increase since 7:00 on October 3)	O.P.+ 3,290 mm (26 mm increase since 7:00 on October 3)	O.P.+ 3,162 mm (2 mm decrease since 7:00 on October 3)	O.P.+ 2,887 mm (7 mm decrease since 7:00 on October 3)
	Water level of Reactor Building	O.P.+ 4,860 mm (11 mm increase since 7:00 on October 3)	O.P.+ 3,541 mm (49 mm increase since 7:00 on October 3)	O.P.+ 3,331 mm (5 mm increase since 7:00 on October 3)	O.P.+ 2,903 mm (4 mm decrease since 7:00 on October 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,203 mm (Increase from initial level:4,420 mm, 93 mm increase since 7:00 on October 3) O.P.+ 3,539 mm (Increase from initial level:4,265 mm, 105 mm increase since 7:00 on October 3) O.P.+ 4,437 mm (Water level from floor:641 mm, 1 mm increase since 7:00 on October 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:20 on September 28)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:59 on September 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.