

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 4)**

Water Level of the accumulated water (at 7:00 on October 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,353 mm (78 mm increase since 16:00 on October 3)	O.P.+ 3,195 mm (32 mm increase since 16:00 on October 3)	—
	Water level of Turbine Building	O.P.+ 2,841 mm (41 mm increase since 16:00 on October 3)	O.P.+ 3,358 mm (68 mm increase since 16:00 on October 3)	O.P.+ 3,200 mm (38 mm increase since 16:00 on October 3)	O.P.+ 2,900 mm (13 mm increase since 16:00 on October 3)
	Water level of Reactor Building	O.P.+ 5,092 mm (232 mm increase since 16:00 on October 3)	O.P.+ 3,617 mm (76 mm increase since 16:00 on October 3)	O.P.+ 3,384 mm (53 mm increase since 16:00 on October 3)	O.P.+ 2,920 mm (17 mm increase since 16:00 on October 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,337 mm (Increase from initial level:4,554 mm, 134 mm increase since 16:00 on October 3) O.P.+ 3,602 mm (Increase from initial level:4,328 mm, 63 mm increase since 16:00 on October 3) O.P.+ 4,440 mm (Water level from floor:644 mm, 3 mm increase since 16:00 on October 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:20 on September 28)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:59 on September 25   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.