

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 5)**

Water Level of the accumulated water (at 7:00 on October 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,358 mm (13 mm decrease since 16:00 on October 4)	O.P.+ 3,244 mm (19 mm increase since 16:00 on October 4)	—
	Water level of Turbine Building	O.P.+ 2,968 mm (56 mm increase since 16:00 on October 4)	O.P.+ 3,363 mm (11 mm decrease since 16:00 on October 4)	O.P.+ 3,240 mm (15 mm increase since 16:00 on October 4)	O.P.+ 2,899 mm (6 mm decrease since 16:00 on October 4)
	Water level of Reactor Building	O.P.+ 5,312 mm (74 mm increase since 16:00 on October 4)	O.P.+ 3,605 mm (23 mm decrease since 16:00 on October 4)	O.P.+ 3,398 mm (6 mm increase since 16:00 on October 4)	O.P.+ 2,911 mm (6 mm decrease since 16:00 on October 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,675 mm (Increase from initial level:4,892 mm, 209 mm increase since 16:00 on October 4) O.P.+ 3,361 mm (Increase from initial level:4,087 mm, 181 mm decrease since 16:00 on October 4) O.P.+ 4,443 mm (Water level from floor:647 mm, 2 mm increase since 16:00 on October 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:19 on October 4)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 4)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:20 on September 28)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:55 on October 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.