

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 5)**

Water Level of the accumulated water (at 16:00 on October 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,349 mm (9 mm decrease since 7:00 on October 5)	O.P.+ 3,249 mm (5 mm increase since 7:00 on October 5)	—
	Water level of Turbine Building	O.P.+ 2,991 mm (23 mm increase since 7:00 on October 5)	O.P.+ 3,356 mm (7 mm decrease since 7:00 on October 5)	O.P.+ 3,245 mm (5 mm increase since 7:00 on October 5)	O.P.+ 2,895 mm (4 mm decrease since 7:00 on October 5)
	Water level of Reactor Building	O.P.+ 5,323 mm (11 mm increase since 7:00 on October 5)	O.P.+ 3,597 mm (8 mm decrease since 7:00 on October 5)	O.P.+ 3,403 mm (5 mm increase since 7:00 on October 5)	O.P.+ 2,907 mm (4 mm decrease since 7:00 on October 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,803 mm (Increase from initial level:5,020 mm, 128 mm increase since 7:00 on October 5) O.P.+ 3,259 mm (Increase from initial level:3,985 mm, 102 mm decrease since 7:00 on October 5) O.P.+ 4,446 mm (Water level from floor:650 mm, 3 mm increase since 7:00 on October 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:19 on October 4)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 4)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:20 on September 28)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:55 on October 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.