

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 9)**

Water Level of the accumulated water (at 7:00 on October 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,298 mm (14 mm increase since 16:00 on October 8)	O.P.+ 3,224 mm (9 mm decrease since 16:00 on October 8)	—
	Water level of Turbine Building	O.P.+ 2,849 mm (208 mm decrease since 16:00 on October 8)	O.P.+ 3,307 mm (12 mm increase since 16:00 on October 8)	O.P.+ 3,219 mm (9 mm decrease since 16:00 on October 8)	O.P.+ 2,849 mm (7 mm decrease since 16:00 on October 8)
	Water level of Reactor Building	O.P.+ 5,076 mm (45 mm decrease since 16:00 on October 8)	O.P.+ 3,550 mm (11 mm increase since 16:00 on October 8)	O.P.+ 3,382 mm (9 mm decrease since 16:00 on October 8)	O.P.+ 2,861 mm (7 mm decrease since 16:00 on October 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,690 mm (Increase from initial level:5,907 mm, 2 mm decrease since 16:00 on October 8) O.P.+ 2,881 mm (Increase from initial level:3,607 mm, 219 mm increase since 16:00 on October 8) O.P.+ 4,460 mm (Water level from floor:664 mm, 3 mm increase since 16:00 on October 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building →Basement of Unit 2 Turbine Building Currently being transferred (Since 10:46 on October 8)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:19 on October 4)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 4)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:20 on October 8)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:55 on October 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.