

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 10)**

Water Level of the accumulated water (at 7:00 on October 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,268 mm (23 mm decrease since 16:00 on October 9)	O.P.+ 3,220 mm (1 mm increase since 16:00 on October 9)	—
	Water level of Turbine Building	O.P.+ 2,841 mm (26 mm increase since 16:00 on October 9)	O.P.+ 3,280 mm (21 mm decrease since 16:00 on October 9)	O.P.+ 3,206 mm (9 mm decrease since 16:00 on October 9)	O.P.+ 2,908 mm (43 mm increase since 16:00 on October 9)
	Water level of Reactor Building	O.P.+ 5,021 mm (27 mm decrease since 16:00 on October 9)	O.P.+ 3,535 mm (18 mm decrease since 16:00 on October 9)	O.P.+ 3,367 mm (9 mm decrease since 16:00 on October 9)	O.P.+ 2,891 mm (24 mm increase since 16:00 on October 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,693 mm (Increase from initial level:5,910 mm, 1 mm increase since 16:00 on October 9) O.P.+ 2,739 mm (Increase from initial level:3,465 mm, 144 mm decrease since 16:00 on October 9) O.P.+ 4,463 mm (Water level from floor:667 mm, 2 mm increase since 16:00 on October 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:19 on October 4)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:55 on October 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.