

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 10)**

Water Level of the accumulated water (at 16:00 on October 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,254 mm (14 mm decrease since 7:00 on October 10)	O.P.+ 3,220 mm (No change since 7:00 on October 10)	—
	Water level of Turbine Building	O.P.+ 2,857 mm (16 mm increase since 7:00 on October 10)	O.P.+ 3,268 mm (12 mm decrease since 7:00 on October 10)	O.P.+ 3,203 mm (3 mm decrease since 7:00 on October 10)	O.P.+ 2,931 mm (23 mm increase since 7:00 on October 10)
	Water level of Reactor Building	O.P.+ 5,014 mm (7 mm decrease since 7:00 on October 10)	O.P.+ 3,523 mm (12 mm decrease since 7:00 on October 10)	O.P.+ 3,364 mm (3 mm decrease since 7:00 on October 10)	O.P.+ 2,908 mm (17 mm increase since 7:00 on October 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,698 mm (Increase from initial level:5,915 mm, 5 mm increase since 7:00 on October 10) O.P.+ 2,665 mm (Increase from initial level:3,391 mm, 74 mm decrease since 7:00 on October 10) O.P.+ 4,463 mm (Water level from floor:667 mm, No change since 7:00 on October 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:19 on October 4)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:55 on October 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.