

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 11)**

Water Level of the accumulated water (at 7:00 on October 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,230 mm (24 mm decrease since 16:00 on October 10)	O.P.+ 3,223 mm (3 mm increase since 16:00 on October 10)	—
	Water level of Turbine Building	O.P.+ 2,884 mm (27 mm increase since 16:00 on October 10)	O.P.+ 3,248 mm (20 mm decrease since 16:00 on October 10)	O.P.+ 3,200 mm (3 mm decrease since 16:00 on October 10)	O.P.+ 2,969 mm (38 mm increase since 16:00 on October 10)
	Water level of Reactor Building	O.P.+ 4,929 mm (85 mm decrease since 16:00 on October 10)	O.P.+ 3,508 mm (15 mm decrease since 16:00 on October 10)	O.P.+ 3,362 mm (2 mm decrease since 16:00 on October 10)	O.P.+ 2,937 mm (29 mm increase since 16:00 on October 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,699 mm (Increase from initial level:5,916 mm, 1 mm increase since 16:00 on October 10) O.P.+ 2,539 mm (Increase from initial level:3,265 mm, 126 mm decrease since 16:00 on October 10) O.P.+ 4,466 mm (Water level from floor:670 mm, 3 mm increase since 16:00 on October 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:19 on October 4)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:30 on October 11 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:30 AM on October 11, the second cesium absorption apparatus (SARRY) was temporarily stopped for filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.