

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 11)

Water Level of the accumulated water (at 16:00 on October 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,217 mm (13 mm decrease since 7:00 on October 11)	O.P.+ 3,224 mm (1 mm increase since 7:00 on October 11)	—
	Water level of Turbine Building	O.P.+ 2,898 mm (14 mm increase since 7:00 on October 11)	O.P.+ 3,237 mm (11 mm decrease since 7:00 on October 11)	O.P.+ 3,200 mm (No change since 7:00 on October 11)	O.P.+ 2,988 mm (19 mm increase since 7:00 on October 11)
	Water level of Reactor Building	O.P.+ 4,906 mm (23 mm decrease since 7:00 on October 11)	O.P.+ 3,495 mm (13 mm decrease since 7:00 on October 11)	O.P.+ 3,361 mm (1 mm decrease since 7:00 on October 11)	O.P.+ 2,954 mm (17 mm increase since 7:00 on October 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,704 mm (Increase from initial level:5,921 mm, 5 mm increase since 7:00 on October 11) O.P.+ 2,660 mm (Increase from initial level:3,386 mm, 121 mm increase since 7:00 on October 11) O.P.+ 4,467 mm (Water level from floor:671 mm, 4 mm increase since 7:00 on October 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:19 on October 4)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:13 on October 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:30 AM on October 11, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning. At 12:15 PM on the same day, the apparatus was restarted after the filter cleaning was completed, and the steady flow rate was achieved at 1:13 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.