

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 12)**

Water Level of the accumulated water (at 7:00 on October 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,196 mm (21 mm decrease since 16:00 on October 11)	O.P.+ 3,229 mm (5 mm increase since 16:00 on October 11)	—
	Water level of Turbine Building	O.P.+ 2,922 mm (24 mm increase since 16:00 on October 11)	O.P.+ 3,217 mm (20 mm decrease since 16:00 on October 11)	O.P.+ 3,200 mm (No change since 16:00 on October 11)	O.P.+ 3,019 mm (31 mm increase since 16:00 on October 11)
	Water level of Reactor Building	O.P.+ 4,878 mm (28 mm decrease since 16:00 on October 11)	O.P.+ 3,475 mm (20 mm decrease since 16:00 on October 11)	O.P.+ 3,361 mm (No change since 16:00 on October 11)	O.P.+ 2,980 mm (26 mm increase since 16:00 on October 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,704 mm (Increase from initial level:5,921 mm, No change since 16:00 on October 11) O.P.+ 2,528 mm (Increase from initial level:3,254 mm, 132 mm decrease since 16:00 on October 11) O.P.+ 4,469 mm (Water level from floor:673 mm, 2 mm increase since 16:00 on October 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:19 on October 4)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:13 on October 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.