

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 12)**

Water Level of the accumulated water (at 16:00 on October 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,182 mm (14 mm decrease since 7:00 on October 12)	O.P.+ 3,231 mm (2 mm increase since 7:00 on October 12)	—
	Water level of Turbine Building	O.P.+ 2,936 mm (14 mm increase since 7:00 on October 12)	O.P.+ 3,205 mm (12 mm decrease since 7:00 on October 12)	O.P.+ 3,200 mm (No change since 7:00 on October 12)	O.P.+ 3,037 mm (18 mm increase since 7:00 on October 12)
	Water level of Reactor Building	O.P.+ 4,852 mm (26 mm decrease since 7:00 on October 12)	O.P.+ 3,462 mm (13 mm decrease since 7:00 on October 12)	O.P.+ 3,362 mm (1 mm increase since 7:00 on October 12)	O.P.+ 2,994 mm (14 mm increase since 7:00 on October 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,708 mm (Increase from initial level:5,925 mm, 4 mm increase since 7:00 on October 12) O.P.+ 2,450 mm (Increase from initial level:3,176 mm, 78 mm decrease since 7:00 on October 12) O.P.+ 4,469 mm (Water level from floor:673 mm, No change since 7:00 on October 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:19 on October 4)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:13 on October 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.