

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 15)**

Water Level of the accumulated water (at 7:00 on October 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,193 mm (54 mm increase since 16:00 on October 14)	O.P.+ 3,201 mm (33 mm decrease since 16:00 on October 14)	—
	Water level of Turbine Building	O.P.+ 3,026 mm (21 mm increase since 16:00 on October 14)	O.P.+ 3,213 mm (47 mm increase since 16:00 on October 14)	O.P.+ 3,140 mm (43 mm decrease since 16:00 on October 14)	O.P.+ 3,126 mm (8 mm increase since 16:00 on October 14)
	Water level of Reactor Building	O.P.+ 4,668 mm (33 mm decrease since 16:00 on October 14)	O.P.+ 3,450 mm (45 mm increase since 16:00 on October 14)	O.P.+ 3,305 mm (47 mm decrease since 16:00 on October 14)	O.P.+ 3,091 mm (18 mm increase since 16:00 on October 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,712 mm (Increase from initial level:5,929 mm, 1 mm increase since 16:00 on October 14) O.P.+ 1,926 mm (Increase from initial level:2,652 mm, 122 mm decrease since 16:00 on October 14) O.P.+ 4,473 mm (Water level from floor:677 mm, 1 mm increase since 16:00 on October 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:13 on October 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.