

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 15)**

Water Level of the accumulated water (at 16:00 on October 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,221 mm (28 mm increase since 7:00 on October 15)	O.P.+ 3,198 mm (3 mm decrease since 7:00 on October 15)	—
	Water level of Turbine Building	O.P.+ 3,035 mm (9 mm increase since 7:00 on October 15)	O.P.+ 3,238 mm (25 mm increase since 7:00 on October 15)	O.P.+ 3,145 mm (5 mm increase since 7:00 on October 15)	O.P.+ 3,109 mm (17 mm decrease since 7:00 on October 15)
	Water level of Reactor Building	O.P.+ 4,654 mm (14 mm decrease since 7:00 on October 15)	O.P.+ 3,475 mm (25 mm increase since 7:00 on October 15)	O.P.+ 3,302 mm (3 mm decrease since 7:00 on October 15)	O.P.+ 3,098 mm (7 mm increase since 7:00 on October 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,712 mm (Increase from initial level:5,929 mm, No change since 7:00 on October 15) O.P.+ 1,832 mm (Increase from initial level:2,558 mm, 94 mm decrease since 7:00 on October 15) O.P.+ 4,474 mm (Water level from floor:678 mm, 1 mm increase since 7:00 on October 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:43 on October 4 to 10:18 on October 15)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:55 on October 15)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:13 on October 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.