

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 17)**

Water Level of the accumulated water (at 16:00 on October 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,197 mm (20 mm decrease since 7:00 on October 17)	O.P.+ 3,173 mm (4 mm increase since 7:00 on October 17)	—
	Water level of Turbine Building	O.P.+ 3,091 mm (9 mm increase since 7:00 on October 17)	O.P.+ 3,218 mm (17 mm decrease since 7:00 on October 17)	O.P.+ 3,140 mm (6 mm increase since 7:00 on October 17)	O.P.+ 3,007 mm (14 mm decrease since 7:00 on October 17)
	Water level of Reactor Building	O.P.+ 4,604 mm (8 mm decrease since 7:00 on October 17)	O.P.+ 3,476 mm (15 mm decrease since 7:00 on October 17)	O.P.+ 3,301 mm (10 mm increase since 7:00 on October 17)	O.P.+ 3,014 mm (12 mm decrease since 7:00 on October 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,720 mm (Increase from initial level:5,937 mm, 1 mm increase since 7:00 on October 17) O.P.+ 2,259 mm (Increase from initial level:2,985 mm, 84 mm increase since 7:00 on October 17) O.P.+ 4,476 mm (Water level from floor:680 mm, 1 mm increase since 7:00 on October 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on October 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:05 on October 15)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:55 on October 15)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:13 on October 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.