

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 18)**

Water Level of the accumulated water (at 7:00 on October 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,177 mm (20 mm decrease since 16:00 on October 17)	O.P.+ 3,197 mm (24 mm increase since 16:00 on October 17)	—
	Water level of Turbine Building	O.P.+ 3,111 mm (20 mm increase since 16:00 on October 17)	O.P.+ 3,200 mm (18 mm decrease since 16:00 on October 17)	O.P.+ 3,172 mm (32 mm increase since 16:00 on October 17)	O.P.+ 2,995 mm (12 mm decrease since 16:00 on October 17)
	Water level of Reactor Building	O.P.+ 4,685 mm (81 mm increase since 16:00 on October 17)	O.P.+ 3,464 mm (12 mm decrease since 16:00 on October 17)	O.P.+ 3,334 mm (33 mm increase since 16:00 on October 17)	O.P.+ 3,004 mm (10 mm decrease since 16:00 on October 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,721 mm (Increase from initial level:5,938 mm, 1 mm increase since 16:00 on October 17) O.P.+ 2,403 mm (Increase from initial level:3,129 mm, 144 mm increase since 16:00 on October 17) O.P.+ 4,477 mm (Water level from floor:681 mm, 1 mm increase since 16:00 on October 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on October 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:05 on October 15)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:55 on October 15)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:29 on October 18 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:29 AM on July 18, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.