

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 19)**

Water Level of the accumulated water (at 16:00 on October 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,122 mm (14 mm decrease since 7:00 on October 19)	O.P.+ 3,222 mm (4 mm increase since 7:00 on October 19)	—
	Water level of Turbine Building	O.P.+ 3,151 mm (10 mm increase since 7:00 on October 19)	O.P.+ 3,150 mm (13 mm decrease since 7:00 on October 19)	O.P.+ 3,196 mm (4 mm increase since 7:00 on October 19)	O.P.+ 2,955 mm (10 mm decrease since 7:00 on October 19)
	Water level of Reactor Building	O.P.+ 4,703 mm (4 mm decrease since 7:00 on October 19)	O.P.+ 3,401 mm (16 mm decrease since 7:00 on October 19)	O.P.+ 3,359 mm (6 mm increase since 7:00 on October 19)	O.P.+ 2,966 mm (9 mm decrease since 7:00 on October 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,803 mm (Increase from initial level:6,020 mm, 1 mm increase since 7:00 on October 19) O.P.+ 2,976 mm (Increase from initial level:3,702 mm, 107 mm increase since 7:00 on October 19) O.P.+ 4,231 mm (Water level from floor:435 mm, No change since 7:00 on October 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on October 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:05 on October 15)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:55 on October 15)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:21 on October 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- In our previous report (as of 6:00 PM on October 18, 2012), we announced "at 4:00 PM on the same day, we manually stopped SARRY by closing the filter entrance valve." We correct it as "at 3:53 PM on the same day." Please accept our apologies for this mistake. (As of October 19, 2012)				

For quick publication of the data of water level, values are provided as reference values.