

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 22)**

Water Level of the accumulated water (at 16:00 on October 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,200 mm (28 mm increase since 7:00 on October 22)	O.P.+ 3,149 mm (27 mm decrease since 7:00 on October 22)	—
	Water level of Turbine Building	O.P.+ 2,879 mm (12 mm increase since 7:00 on October 22)	O.P.+ 3,218 mm (23 mm increase since 7:00 on October 22)	O.P.+ 3,093 mm (30 mm decrease since 7:00 on October 22)	O.P.+ 2,976 mm (16 mm increase since 7:00 on October 22)
	Water level of Reactor Building	O.P.+ 4,606 mm (9 mm decrease since 7:00 on October 22)	O.P.+ 3,455 mm (25 mm increase since 7:00 on October 22)	O.P.+ 3,260 mm (34 mm decrease since 7:00 on October 22)	O.P.+ 2,969 mm (16 mm increase since 7:00 on October 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,809 mm (Increase from initial level:6,026 mm, 1 mm increase since 7:00 on October 22) O.P.+ 2,997 mm (Increase from initial level:3,723 mm, 143 mm decrease since 7:00 on October 22) O.P.+ 4,235 mm (Water level from floor:439 mm, 1 mm decrease since 7:00 on October 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:05 on October 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:21 on October 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.