

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 23)**

Water Level of the accumulated water (at 7:00 on October 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,243 mm (43 mm increase since 16:00 on October 22)	O.P.+ 3,112 mm (37 mm decrease since 16:00 on October 22)	—
	Water level of Turbine Building	O.P.+ 2,897 mm (18 mm increase since 16:00 on October 22)	O.P.+ 3,257 mm (39 mm increase since 16:00 on October 22)	O.P.+ 3,048 mm (45 mm decrease since 16:00 on October 22)	O.P.+ 3,011 mm (35 mm increase since 16:00 on October 22)
	Water level of Reactor Building	O.P.+ 4,605 mm (1 mm decrease since 16:00 on October 22)	O.P.+ 3,496 mm (41 mm increase since 16:00 on October 22)	O.P.+ 3,213 mm (47 mm decrease since 16:00 on October 22)	O.P.+ 2,987 mm (18 mm increase since 16:00 on October 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,811 mm (Increase from initial level:6,028 mm, 2 mm increase since 16:00 on October 22) O.P.+ 2,780 mm (Increase from initial level:3,506 mm, 217 mm decrease since 16:00 on October 22) O.P.+ 4,236 mm (Water level from floor:440 mm, 1 mm increase since 16:00 on October 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (From 18:05 on October 15 to 8:46 on October 23)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:21 on October 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.