

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 23)**

Water Level of the accumulated water (at 16:00 on October 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,269 mm (26 mm increase since 7:00 on October 23)	O.P.+ 3,109 mm (3 mm decrease since 7:00 on October 23)	—
	Water level of Turbine Building	O.P.+ 2,907 mm (10 mm increase since 7:00 on October 23)	O.P.+ 3,280 mm (23 mm increase since 7:00 on October 23)	O.P.+ 3,041 mm (7 mm decrease since 7:00 on October 23)	O.P.+ 3,008 mm (3 mm decrease since 7:00 on October 23)
	Water level of Reactor Building	O.P.+ 4,607 mm (2 mm increase since 7:00 on October 23)	O.P.+ 3,519 mm (23 mm increase since 7:00 on October 23)	O.P.+ 3,202 mm (11 mm decrease since 7:00 on October 23)	O.P.+ 2,998 mm (11 mm increase since 7:00 on October 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,812 mm (Increase from initial level:6,029 mm, 1 mm increase since 7:00 on October 23) O.P.+ 2,601 mm (Increase from initial level:3,327 mm, 179 mm decrease since 7:00 on October 23) O.P.+ 4,236 mm (Water level from floor:440 mm, No change since 7:00 on October 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:07 on October 23)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:21 on October 18   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- From 6:05 PM on October 15 to 8:46 AM on October 23, the accumulated water in Unit 3 Turbine Building basement was transferred to the Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building).				

For quick publication of the data of water level, values are provided as reference values.