

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 24)**

Water Level of the accumulated water (at 7:00 on October 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,312 mm (43 mm increase since 16:00 on October 23)	O.P.+ 3,094 mm (15 mm decrease since 16:00 on October 23)	—
	Water level of Turbine Building	O.P.+ 2,924 mm (17 mm increase since 16:00 on October 23)	O.P.+ 3,316 mm (36 mm increase since 16:00 on October 23)	O.P.+ 3,019 mm (22 mm decrease since 16:00 on October 23)	O.P.+ 3,012 mm (4 mm increase since 16:00 on October 23)
	Water level of Reactor Building	O.P.+ 4,626 mm (19 mm increase since 16:00 on October 23)	O.P.+ 3,554 mm (35 mm increase since 16:00 on October 23)	O.P.+ 3,179 mm (23 mm decrease since 16:00 on October 23)	O.P.+ 3,013 mm (15 mm increase since 16:00 on October 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,813 mm (Increase from initial level:6,030 mm, 1 mm increase since 16:00 on October 23) O.P.+ 2,430 mm (Increase from initial level:3,156 mm, 171 mm decrease since 16:00 on October 23) O.P.+ 4,237 mm (Water level from floor:441 mm, 1 mm increase since 16:00 on October 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 13:07 on October 23 to 8:11 on October 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:21 on October 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.